



CARRIER PIPE NOMINAL Dia	CASING PIPE		MINIMUM RUNNER SIZE
	Min O.D.	Min WALL THICKNESS	
4"	12"	0.188"	2" x 4"
6"	16"	0.25"	2" x 4"
8"	18"	0.282"	2" x 4"
12"	22"	0.344"	2" x 4"
16"	28"	0.406"	2" x 6"
20"	32"	0.469"	2" x 6"

NOTES:

1. NEOPRENE OR PVC RUNNERS MAY BE USED AS AN ALTERNATIVE TO TREATED REDWOOD.
2. TRENCH LAID CASINGS SHALL BE DESIGNED AND INSTALLED TO CONDUIT STANDARDS.

DENVER WATER 1600 West 12th Avenue • Denver, Colorado 80204 Phone (303) 628-6000 • Telecopier No. (303) 628-6851		
<h2>BORE CASING DETAIL</h2>		
Scale: <u>NONE</u>	Date: <u>JULY 1995</u>	
Drawn: <u>C.B.B.</u>	Tr: <u> </u>	Ck: <u> </u>
Approved: <u> </u>		Dr. <u>127</u> No. <u>35</u>